

EU/UKCA Declaration of Conformity (No. 21010)

In accordance with European Parliament and Council Decision No 768/2008/EC Annex III and BS EN ISO/IEC 17050-1:2010

1. Product Identification:

Product Smoke Alarm

2. Manufacturer:

Name FireAngel Safety Technology Limited
Address Vanguard centre, Sir William Lyons Road, Coventry, CV4 7EZ, UK

EU Authorised Representative:

Name Authorised Representative Service
Address 77 Camden Street Lower, Dublin, D02 XE80, Ireland

3. This Declaration of Conformity is issued under the sole responsibility of the Manufacturer:

4. Object of the declaration:

Product Smoke Alarm Device
Model/type FireAngel SW1, FireAngel SW10
Description Mains Powered smoke alarm with Battery Backup for domestic applications
Specification Mains 230VAC replaceable 9V battery backup. Hardwired interconnect

5. The object of the declaration described above is in conformity with the relevant Union harmonisation legislation and Statutory Instruments:

6. Legislation and standards:

UK CA UK (UKCA) Legislation	CE EU (CE) Legislation	Designated, Harmonised and other standards showing compliance
Construction Products Regulation (EU) No. 305/2011, as amended by The Construction Products (Amendment Etc) (EU Exit) Regulations 2019, 2020 and 2022.	Construction Products Regulation 305/2011/EU	EN14604:2005/AC:2008
The Electrical Equipment (Safety) Regulations 2016/1101	The Low Voltage Directive 2014/35/EU	EN 62368-1_2014+A11_2017
The Electromagnetic Compatibility Regulations 2016/1091	The Electromagnetic Compatibility Directive 2014/30/EU	EN 50130-4:2011+A1:2014 EN 61000-6-3:2007/A1:2011/AC:2012
The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012/3032	The Restriction of Hazardous Substances Directive 2011/65/EU	EN IEC 63000:2018

7. The notified body Intertek Deutschland GMBH, Stangenstraße 1, 70771 Leinfelden-Echterdingen. Germany issued certificates 0905-CPR-00650 in accordance with EN14604:2005+AC:2008.

The UK approved body Intertek, Unit C, Imperial Park, Randalls Way, Leatherhead, KT22 7TA issued certificates 0359-UKCA-CPR-00221 in accordance with EN14604:2005+AC:2008

8. Authorisation and signature

Signed for and on behalf of: FireAngel Safety Technology Limited
Place of issue: Coventry, United Kingdom
Date of 1st issue: 1st November 2021
Revision date: 5th September 2022
Revision: 1.01
Name: Ian Ballinger
Function: Head of Certification
Signature:

